

Refuelling Site Safety Checklist

10 Steps to a safer refuelling area

Prepared by Richard Sykes & Jason Unsworth



www.octane.uk.com

info@octane.uk.com

2019 Edition

10 Step Refuelling Safety Checklist

Site:

Checked By:

Date:

- Tank correctly labelled?
- Audible overfill alarm installed?
- Weekly housekeeping routine?
- Do you have a drainage plan?
- Does your stock reconciliation numbers add up against your gauges?
- Out of hours emergency plan?
- Refuelling system electrics tested recently?
- Emergency stop button easily located?
- Safety breakaway coupling installed?
- Is the fuel dispenser housing secure?



SITE AUDIT & RISK ASSESSMENT (SARA)

Is your refuelling site operating safely
and in-line with regulations?

[Find Out More](#)